

## **GLADSTONE EMERGENCY REPAIR**

### **Bullet Points**

- **This ordinance is necessary to replace an existing 24-inch sanitary sewer on Gladstone that is deteriorating and causing a sinkhole.**
- The 24-inch sewer is over 100 years old, has had two repairs made in the past few years and is now “oblong” instead of “round” due to its deteriorating condition.
- Sufficient funds are available within the Sewer Replacement Fund to pay for this replacement.