



Legislation Details (With Text)

File #: O-024-24 **Version:** 2 **Name:**
Type: Ordinance **Status:** Approved
File created: 10/10/2023 **In control:** Water Quality & Sustainability Committee
On agenda: 1/17/2024 **Final action:** 1/17/2024
Title: Authorizing the expenditure of \$43,420 from the Sewer Replacement Fund to pay Meldrum Mechanical Services, Inc. (Meldrum) for emergency assistance to complete maintenance projects at the Bayview Water Reclamation Plant; finding that the competitive procurement process was waived under TMC Section 187.20; and declaring an emergency.

Sponsors:

Indexes:

Code sections:

Attachments: 1. Video: Agenda Review 10/17/2023, 2. Video: Agenda Review 10/31/2023, 3. Video: City Council 11/8/2023, 4. Video: Agenda Review 11/14/2023, 5. Video: City Council 11/21/2023, 6. Video: City Council 1/17/2024

Date	Ver.	Action By	Action	Result
1/17/2024	2	City Council	relieve of Committee	Pass
1/17/2024	2	City Council	Emergency	Pass
1/17/2024	2	City Council	Passage	Pass
11/21/2023	1	City Council	Referred To:	Pass
11/8/2023	1	City Council	held	Pass
10/24/2023	1	City Council	First Reading	Pass

DPU102423VariousMechanicalServices
Water Reclamation
Andy McClure (x7866)
[O-573-23]

Authorizing the expenditure of \$43,420 from the Sewer Replacement Fund to pay Meldrum Mechanical Services, Inc. (Meldrum) for emergency assistance to complete maintenance projects at the Bayview Water Reclamation Plant; finding that the competitive procurement process was waived under TMC Section 187.20; and declaring an emergency.

SUMMARY & BACKGROUND:

[O-573-23] The Division has eight outstanding invoices from Meldrum associated with emergency assistance on three events to help assure continued reliable operation of the plant facilities. While preparing for and during removal and replacement of RAS pumps Meldrum provided services that left undone could have resulted in serious permit violations. Meldrum fabricated chain links that drive the bar screen rake at the Bayview Pumping Station so the bar screen could remain in service. There were no links in stock and the OEM vendor could not respond in a timely manner. Without the screen rake, the bar screen would become plugged in a short period of time resulting in a significant loss in pumping capacity. Functional valves are required to isolate sections of the plant for maintenance and repair purposes. Meldrum fabricated repair parts for several large valves on site to restore them to operational service so that necessary repairs elsewhere could be made.

NOW, THEREFORE, Be it ordained by the Council of the City of Toledo:

SECTION 1. That the expenditure of \$43,420 from the Sewer Replacement Fund to Account Code 6073-36000-4UC1723STDSTD for emergency assistance and repairs at the Bayview Water Reclamation Facility is authorized.

SECTION 2. That the mayor is authorized to award an emergency contract to and pay Meldrum for emergency repairs and assistance at the Bayview Water Reclamation Facility, upon terms and conditions approved by the Director of Public Utilities and the Director of Law.

SECTION 3. That Council finds and determines that, pursuant to TMC Chapter 187.20, formal competitive bidding was waived for the reason that it was an emergency that could not have been reasonably foreseen and would result in an interruption or detriment to utility services and the repair cost has been deemed reasonable by the Director of Public Utilities.

SECTION 4. That the Finance Director is authorized to issue their warrant or warrants against the Account Code identified in Section 1 in an amount not to exceed \$43,420 in payment of the obligations authorized above upon presentation of the proper voucher or vouchers.

SECTION 5. That this Ordinance is declared to be an emergency measure and shall take effect and be in force from and after its passage. The reason for the emergency lies in the fact that this Ordinance is necessary for the immediate preservation of the public peace, health, safety and property, and for the further reason that this Ordinance must be immediately effective in order to pay Meldrum for emergency services at the Bayview Water Reclamation Facility.

Vote on emergency clause: yeas 10, nays 0.

Passed: January 17, 2024, as an emergency measure: yeas 10, nays 0.

Attest:

Julie Gibbons
Clerk of Council

Carrie Hartman
President of Council

Approved:

January 22, 2024
Wade Kapszukiewicz
Mayor