



Legislation Details (With Text)

File #: O-255-22 **Version:** 1 **Name:**
Type: Ordinance **Status:** Approved
File created: 5/9/2022 **In control:** Public Utilities Department
On agenda: 5/24/2022 **Final action:** 5/24/2022
Title: Authorizing the appropriation and expenditure in an amount not to exceed \$250,000 from the Sewer Replacement Fund for the Digester Heat Exchanger Project at the Water Reclamation Plant; authorizing the mayor to accept bids and award contracts for equipment and construction services necessary to facilitate the construction of the Digester Heat Exchanger Project; and declaring an emergency.

Sponsors:

Indexes:

Code sections:

Attachments:

Date	Ver.	Action By	Action	Result
5/24/2022	1	City Council	Suspension	Pass
5/24/2022	1	City Council	Emergency	Pass
5/24/2022	1	City Council	Passage	Pass

DPU052422DigesterHeatExchangerProject
Water Reclamation
Mike Schreidah (x2607)
Revised

Authorizing the appropriation and expenditure in an amount not to exceed \$250,000 from the Sewer Replacement Fund for the Digester Heat Exchanger Project at the Water Reclamation Plant; authorizing the mayor to accept bids and award contracts for equipment and construction services necessary to facilitate the construction of the Digester Heat Exchanger Project; and declaring an emergency.

SUMMARY & BACKGROUND:

The Water Reclamation Plant (Plant) has six (6) digester heat exchangers that transfer heat from the boiler system to the pre-digested sludge. This heat transfer is crucial for pathogen and volatile solid reduction in post-digested sludge as required by the Plants NPDES permit. The heat exchangers are 35+ years old and are beyond their useful life.

This project seeks to replace two of the six heat exchangers to enable to the Plant to continue to meet permit obligations.

NOW, THEREFORE, Be it ordained by the Council of the City of Toledo:

SECTION 1. That the appropriation of \$250,000 is authorized from the unappropriated balance of the Sewer Replacement Fund to Account Code 6073-36000-4UC0522STDSTD for equipment and construction

services to facilitate the Digester Heat Exchanger Project at the Water Reclamation Plant; and the expenditure of same is authorized.

SECTION 2. That the mayor is authorized to accept bids and award contracts necessary to complete the Digester Heat Exchanger Project at the Water Reclamation Plant, upon terms and conditions approved by the Director of Public Utilities and the Director of Law.

SECTION 3. That the Finance Director is authorized to issue their warrant or warrants against the Account Code identified in Section 1 in an amount not to exceed \$250,000 in payment of the obligations authorized above upon presentation of the proper voucher or vouchers.

SECTION 4. That the disappropriation of any remaining budget to fund balance is authorized at project closeout.

SECTION 5. That the Ordinance is declared to be an emergency measure and shall take effect and be in force from and after its passage. The reason for the emergency lies in the fact that this Ordinance is necessary for the immediate preservation of the public peace, health, safety and property, and for the further reason that this Ordinance must be immediately effective in order to maintain the operational integrity of the Water Reclamation Plant, and to maintain compliance with the NPDES discharge permit requirements, as set forth by the Ohio EPA.

Vote on emergency clause: yeas _____, nays _____.

Passed: _____, as an emergency measure: yeas _____, nays _____.

Attest: _____
Clerk of Council

President of Council

Approved: _____

Mayor

I hereby certify that the above is a true and correct copy of an Ordinance passed by Council

_____.

Attest: _____
Clerk of Council