

City of Toledo

Legislation Details (With Text)

File #: O-025-24 Version: 2 Name:

Type: Ordinance Status: Approved

File created: 10/10/2023 In control: Water Quality & Sustainability Committee

On agenda: 1/17/2024 Final action: 1/17/2024

Title: Authorizing the expenditure of up to \$24,138 from the Sewer Operating Fund to pay Industrial Power

Systems (IPS) for emergency assistance to recover from a flooding event in the primary clarifier tunnel; finding that the competitive procurement process was waived under TMC Section 187.20; and

declaring an emergency.

Sponsors:

Indexes:

Code sections:

Attachments: 1. Video: Agenda Review 10/17/2023, 2. Video: Agenda Review 10/31/2023, 3. Video: City Council

11/8/2023, 4. Video: Agenda Review 11/14/2023, 5. Video: City Council 11/21/2023, 6. Video: City

Council 1/17/2024

Date	Ver.	Action By	Action	Result
1/17/2024	2	City Council	relieve of Committee	Pass
1/17/2024	2	City Council	Emergency	Pass
1/17/2024	2	City Council	Passage	Pass
11/21/2023	1	City Council	Referred To:	Pass
11/8/2023	1	City Council	held	Pass
10/24/2023	1	City Council	First Reading	Pass

DPU102423PRIMARYSLUDGEPUMPSERVICERECOVERYPROJECT

Water Reclamation Andy McClure (x7866)

[O-574-23]

Authorizing the expenditure of up to \$24,138 from the Sewer Operating Fund to pay Industrial Power Systems (IPS) for emergency assistance to recover from a flooding event in the primary clarifier tunnel; finding that the competitive procurement process was waived under TMC Section 187.20; and declaring an emergency.

SUMMARY & BACKGROUND:

[O-574-23] The Primary Clarifier Tunnel at the Bayview Water Reclamation Facility includes piping, valves, pumps and appurtenances that convey primary sludge, which settles in the primary clarifiers, to the gravity thickener tanks. The sludge has to be removed from the tanks on a regular basis to prevent the collection mechanism from overloading and keep the sludge from becoming so thick that it can't be pumped. The flooding event submerged the pumps and motors that are utilized to move the sludge from the clarifiers to the thickeners. To avoid potential treatment violations and significant expense to clean the tanks after becoming plugged, it was imperative that the pumps be restored to service as quickly as possible. This required removing the motors to be serviced and replaced as needed. IPS was contacted to come in and assist with removal of compromised motors and installation of new motors to restore operation of the sludge removal system.

NOW, THEREFORE, Be it ordained by the Council of the City of Toledo:

SECTION 1. That the expenditure of \$24,138 from the Sewer Operating Fund to Account Code 6070-36000-4000507STDSTD for emergency recovery efforts to the Primary Sludge Pumps in the Primary Tunnel is authorized.

SECTION 2. That the mayor is authorized to award an emergency contract to and pay IPS for emergency recovery efforts to the Primary Sludge Pumps in the Primary Tunnel, upon terms and conditions approved by the Director of Public Utilities and the Director of Law.

SECTION 3. That Council finds and determines that, pursuant to TMC Chapter 187.20, formal competitive bidding was waived for the reason that it was an emergency that could not have been reasonably foreseen and would result in an interruption or detriment to utility services and the repair cost has been deemed reasonable by the Director of Public Utilities.

SECTION 4. That the Finance Director is authorized to issue their warrant or warrants against the Account Code identified in Section 1 in an amount not to exceed \$24,138 in payment of the obligations authorized above upon presentation of the proper voucher or vouchers.

SECTION 5. That this Ordinance is declared to be an emergency measure and shall take effect and be in force from and after its passage. The reason for the emergency lies in the fact that this Ordinance is necessary for the immediate preservation of the public peace, health, safety and property, and for the further reason that this Ordinance must be immediately effective in order to pay IPS for emergency recovery efforts to the Primary Sludge Pumps in the Primary Tunnel.

Vote on emergency clause: yeas 10, nays 0.

Passed: January 17, 2024, as an emergency measure: yeas 10, nays 0.

Attest:

Julie Gibbons Carrie Hartman
Clerk of Council President of Council

Approved: January 22, 2024

Wade Kapszukiewicz

Mayor